



Government Of West Bengal
Office Of The Divisional Fire Officer, North 24 Parganas
West Bengal Fire & Emergency Services
Ghoshpara Road, P.O.:- Bengal Enamel, Pin :- 743122

Memo no.:FSR/0125186221100291

Date: 02-12-2022

From:

Divisional Fire Officer, North 24 Parganas
West Bengal Fire & Emergency Services

To: HERITAGE MODEL SCHOOL

VILL-BARDHANBERIA, P.O-BAIRAMPUR, P.S-GOPALNAGAR, DIST-NORTH 24 PGS, DAG NO-320,325/1157, KH NO-993,994,995,996,997

Sub: Fire Safety Certificate for an existing construction of G+I storied building under group of Educational Institution at the premises: VILL-BARDHANBERIA, P.O-BAIRAMPUR, P.S-GOPALNAGAR, DIST-NORTH 24 PGS, DAG NO-320,325/1157, and KH NO-993,994,995,996,997 in the name & style as "HERITAGE MODEL SCHOOL"

This is in reference to your application no. 0125189221100364 dated 22-11-2022 regarding the Fire Safety Certificate for an existing construction of G+I storied building under group of Educational Institution at the premises: VILL-BARDHANBERIA, P.O-BAIRAMPUR, P.S-GOPALNAGAR, DIST-NORTH 24 PGS, DAG NO-320,325/1157, and KH NO-993,994,995,996,997 in the name & style as "HERITAGE MODEL SCHOOL"

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. The Interior finish decoration of the building shall be made with low flame spread material conforming to the I.S. Specification.
2. Driveway must be free of any type of obstruction for easy movement of fire appliances. No Parking will be allowed on the Drive Way
3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outsides of the building shall be strictly maintained.
4. Fire License shall have to be obtained for proposed storing and processing with L.P.G and other highly combustible articles.
5. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them. Particularly lines above false ceiling & ducts. If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipe continuously bonded to the earth.

6. The Exit Sign & the notice of Fire Fighting equipment's and Evacuation plan shall be maintained and displayed at all venerable places of the building & Mock Fire Practice and Evacuation Drill from the building shall be performed periodically with participants of all the occupants of the building.
7. The employees and security staff shall be conversant with installed Fire Fighting equipment of the building and to operate in the event of Fire and Testing.
8. A crew of trained Fireman under professionally qualified fire personnel shall be maintained round the clock for safety of the building.
9. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
10. Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
11. Periodical flashing of water from the Hydrants shall be made to maintain the efficient working performance of above mentioned system.
12. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
13. This Fire Safety Certificate is valid for three years and have to be renewed from the date of issue of this letter.
14. After three years a certificate is to be obtained from the Divisional Fire Officer, North 24Parganas Division, West Bengal Fire & Emergency Services, performance of all the life & Fire Safety arrangements and installation of the buildings
15. Any deviation/ changes the building in respect of the approved plan drawing, without prior permission from this office, this Fire Safety Certificate will be treated as cancelled.

Divisional Fire Officer, North 24 Parganas
West Bengal Fire & Emergency Services