

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

Memo No. 6403

Dated: 31-07-2024


It is certified that an inspection team headed by Athena Sengupta, from the Water Quality Surveillance under the Public Health Engineering Department Govt. Of West Bengal, inspected the **HERITAGE MODEL SCHOOL** at Village- Bardhanberia, P.O.-Bairampur, PS-Gopalnagar, District - North 24 Parganas, West Bengal – State on **30<sup>th</sup> July 2024** and on the basis of Water Test Report bearing no-P/P22-50 dated **23.04.2024** of PHED Lab certified that **HERITAGE MODEL SCHOOL** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. The school also maintains the hygienic sanitation conditions in the school building and the campus as per norms.

**The above is valid for a period of 01 Years.**

Signature with Seal:

Name:

Designation:

  
Assistant Engineer  
Bongaon Sub-Division  
P.H.E. Dte

To,

**HERITAGE MODEL SCHOOL**

**Village - Bardhanberia, P.O.-Bairampur,**

**PS- Gopalnagar , District - North 24 Parganas , West Bengal**

পাথর  
পাচালি

**Pather Panchali Water Quality Surveillance Project**  
Under PHED, Supported by JPOA with Govt. of West Bengal

Date: 23.04.2024

I.D. No. – P/P22-50

Block: Bongaon

Name of the Owner: Heritage Model School

Location of the Tube well: Heritage Model School

Name of the GP: Bairampur

Name of the Mouza: Bardhanberia, Gopalnagar

Name of Habitation: Rastarpara


Date of Sample Collection: 22.04.2024


Date of testing: 22.04.2024 & 23.04.2024



Sl. No.	Parameter tested	Result	Permissible level as per BIS
01	Arsenic	0.001 mg/l	0.01 mg/l
02	Iron	0.154 mg/l	(0.3 – 1) mg/l
03	pH	7.06	6.5 – 8.5
04	Manganese	0.000 mg/l	(0.01 – 0.03)mg/l
05	Bacteriological Test	TC-0	TC/FC (0)

Remarks: The Sample water is fit for drinking.

  
Signature  
Secretary  
Pather Panchali

  
23/04/24  
Signature  
Chemist/Bacteriologist  
Pather Panchali  
Bacteriologist  
Pather Panchali  
Bongaon, 24 Parganas, W.B.